

DRAFT QUOTE

sam.heynes@cuckfield.gov.uk

Date 2 Mar 2024

Expiry 16 Mar 2024

Quote Number QU-0286

Reference
Cuckfield Village Hall.

VAT Number 437096577

Electrical Hero
4 Blunden Drive
Cuckfield
West Sussex
UNITED KINGDOM
Registered NICEIC:

D610302

VAT number: 437 0965 77

Description	Quantity	Unit Price	VAT	Amount GBP
Rewire: Full rewire of Cuckfield village hall (Fire alarm	1.00	6,500.00	20%	6,500.00

Rewire: Full rewire of Cuckfield village hall (Fire alarm circuit will remain as its was the only circuit that produced higher readings). Scope of work, all ne circuits will be ran in current electrical conduit containment for financial sustainability and for speed of installation. Fuseboard will be replaced with SPD, individual RCBO's (this is to elevate from current situation where the whole hall will trip from one circuit).

All current internal batten lights would be changed as well as the amount, going from 10 to 5 6' 40W LED lights. The vast majority of light switches would also be reduced and changed due to their corroded nature. All external lights would be replaced for more suitable bulk head IP rated light.

Emergency lights: these will need to be change due to the tripping issues and the battery's discharging (pictures have been supplied, these are classed as failures). Finically it is cheaper to replace the unit rather than replace the battery.

New socket circuit will be placed either side of the hall, 4x double metal clad within left side with additional 4 x double for kitchen 2 located above worktop and 2 below for white appliances. Another 4 metal clad double sockets will be place right side of the hall.

Work will be completed over weekend to accommodate use of village hall for preschool and after school clubs. Friday afternoon through to Sunday night. Work will be completed by 3 men.

Price includes all materials, labour and testing.

Subtotal

6,500.00

TOTAL VAT 20%

1,300.00

TOTAL GBP 7,800.00